




	ELECTRICAL SYMBO	DLS	
P ^	CONVENIENCE OUTLET - SET 12" AFF U.N.O. CONVENIENCE OUTLET -42" AFF	VENT TO EXT	
Ф H Ф 220	CONV. OUTLET -MOUNTED HORIZ. IN BACKSPLASH CONV. OUTLET -220 VOLT	FAN / LITE CON VENT TO EX	Т
Ø WP/GFI	CONVENIENCE OUTLET - 1/2 SWITCHED 12" A.F.F. CONV. OUTLET- WATER PROOF- GRND FAULT INTERUPT	EP O	COMPRESSOR
\$\$3\$4	GARAGE DOOR OPENER SWITCH, 3-WAY, 4-WAY- SET 38* AFF U.N.O.	-	CLNG FAN
\$2	STACKED SWITCH	√Âc ③—	CENTRAL VACCUUM OUTLET SECURITY PANEL
4	LIGHT FIXTURE	INTROM	INTERCOM
P P	LIGHT FIXTURE		NON FUSED DISCONNECT SWITCH
©	FLOURESCENT LIGHT	KEY PAD	CONTROL CONSOLE
CHIMES	DOORBELL @ 32* A.F.F.		SECURITY SENSORS ALARM HORN
DB 🗓	ELEC. METER	MD.	MOTION DETECTOR
<u>a</u>	GAS METER	0	JUNCTION BOX @ DISH WASHER THERMOSTAT
T.V.	TELEPHONE OUTLET + 12* A.F.F.	T	DOORBELL TRANSFORMER WEATHER PROOF
♦ so	T.V. OUTLET + 12" A.F.F. SMOKE DETECTOR	W.F	TEATHER PROOF

HVAC SYMBOLS								
EQUIPMENT SY	MBOLS	DUCTWOR	K	HEATING PIP	ING			
EXPOSED RADIATOR		DUCT (1ST FIGURE, WIDT 2ND FIGURE, DEPTH)	TH: 12 X 20	HIGH-PRESSURE STEAM MEDIUM-PRESSURE	A			
RECESSED RADIATOR		DIRECTION OF FLOW		STEAM LOW-PRESSURE STEAM	—LPS—			
FLUSH ENCLOSED RADIATOR		FLEXIBLE CONNECTION		HIGH-PRESSURE RETURN MEDIUM-				
PROJECTING		DUCTWORK WITH ACOUSTICAL LINING	====	PRESSURE RETURN LOW-PRESSURE RETURN				
UNIT HEATER		FIRE DAMPER WITH ACCESS DOOR		BOILER BLOW OFF	so			
(PROPELLER) - PLAN	4	MANUAL VOLUME DAMPER	\Box	CONDENSATE OR VACUUM PUMP DISCHARGE	VP0			
UNIT HEATER (CENTRIFUGAL) - PLAN	000	AUTOMATIC VOLUME DAMPER	\Box	FEEDWATER PUMP DISCHARGE MAKEUP WATER				
UNIT VENTILATOR - PLAN		EXHAUST, RETURN OR OUTSIDE AIR DUCT - SECTION	- 30 X 12	AIR RELIEF LINE	v_			
STEAM	-⊗-	SECTION		FUEL OIL SUCTION	F0G			
DUPLEX STRAINER	-8-	SUPPLY DUCT - SECTION	20 X U	FUEL OIL RETURN	—-FOR-			
PRESSURE-REDUCING VALVE	-B-	CEILING DIFFUSER SUPPLY OUTLET	3F DA CD	FUEL OIL VENT COMPRESSED AIR				
AIR LINE VALVE	⊸	CEILING DIFFUSER SUPPLY OUTLET	20 X 12 CD	HOT WATER HEATING SUPPLY HOT WATER	— ww —			
STRAINER	+ \	LINEAR DIFFUSER	**************************************	AIR CONDITIONING	PIPING			
)		430 CFM		REFRIGERANT LIQUID	— RL —			
THERMOMETER	<u> </u>	FLOOR REGISTER	20 X 13 FR 700 CFM	REFRIGERANT DISCHARGE	— so —			
PRESSURE GAUGE AND COCK	9	TURNING VANES		REFRIGERANT SUCTION CONDENSER	— 85 — — CHS —			
RELIEF VALVE	-\$		п п	WATER SUPPLY CONDENSER WATER RETURN	— CWR			
AUTOMATIC 3-WAY VALVE	- - -	FAN AND MOTOR WITH BELT		CHILLED WATER SUPPLY	—оня—			
AUTOMATIC	4	COAL C	₩	CHILLED WATER RETURN MAKEUP WATER				
2-WAY VALVE	-1×1-			HUMIDIFICATION LINE				
SOLENOID VALVE		LOUVER OPENING	20 X 104 200 CFM	DRAIN				

Common Engineering Drawing Symbols and Meanings



TRAINER.NET®

Common Engineering Drawing Symbols

Job Aid

NFPA 1033—Job Performance Requirement
4.3—Documenting the Scene

4.3.1 Requisite Knowledge and Requisite

Skill



A Product Developed by the IAAI with the Support of a DHS, FEMA, AFG, FPS Grant



Global Leaders in Fire Investigation